

Power grid stability under proportional and derivative control

E.D. Dongmo^{1,2}, D. Gomila², P. Wofo^{1,3} and P. Colet²

¹ Lab. Modelling and Simulation in Engineering and Prototypes, Faculty of Science, University of Yaounde 1, Box 812, Yaounde, Cameroon

² IFISC (CSIC-UIB), Campus Universitat Illes Balears, 07122 Palma de Mallorca, Spain

³ Applied Physics Research Group (APHY), Vrije Universiteit Brussel, Pleinlaan 2, 1050 Brussels, Belgium

This work investigates the resilience of an elementary electricity system (power plant - consumer) under proportional and derivative (PD) control when subject to large perturbations. Two models of power plants are used. The first one is a simple synchronous-motor model with constant power, while the second one includes primary and secondary control to modify the mechanical power to keep the frequency of the system within the statutory limits. A particular attention is paid to small power grids, representative of power grid structure in some developing countries. The considered elementary electrical system consists of a consumer (machine), a power plant (generator) and a transmission line. Runge-Kutta method is used to solve the dynamical equations. In the case where the power plant is modeled with the uncontrolled swing equation [1], it is found that the PD-control increases the resilience of the system [2]. We also show that time delays associated to the feedback loop of the controller have a negative impact on the performance [2]. These effects are also analyzed in the case with frequency control.

-
- [1] E.D Dongmo and P. Wofo, Effects of asymmetry, transmission delay and noises on the stability of an elementary electricity network, *Eur. Phys. J. B*, 88(7), (2015)
- [2] E.D Dongmo, P. Colet and P. Wofo, Power grid enhanced resilience using proportional and derivative control with delayed feedback, *Eur. Phys. J. B*, 90(1), 2017